



NOTE:

1. LATERAL MATERIAL SHALL BE DUCTILE IRON FROM SEWER MAIN TO FIVE FEET PAST THE EDGE OF THE TRENCH.

DEEP SANITARY SEWER SERVICE CONNECTION

NOT TO SCALE